

Electrical

What to Submit

- *Completed application.
- *Plat of plats survey (3 copies)
- *Provide three (3) copies of a site plan showing the proposed exact location of the service meter and the power lines. Include a detail if they are overhead or buried. Provide proposed height of power lines from walking spaces.
- *Provide a detail of the required screening if the unit is placed in the front yard
- *Provide manufacture's installation instructions
- *Provide electric layout detail, including sizing, outlets, lighting/switches if applicable, etc.
- *Confirm clarify in writing that this proposed structure is NOT in a floodplain, easement, or floodway

Rules & Restrictions

- *Everything must be installed per manufacture's installation instructions. Note: each manufacture has different requirements.
- *A permanent plaque shall be installed at each service disconnect and at the meter socket denoting the presence of a generator and its location (Nec 230.2)702.7
- *In general the IRC/NEC requires 36" clearance all around the interior service panel
- *Com Ed requires a 36" clearance all around and above the exterior meter.
- *Call J.U.L.I.E. (800-892-0123) before digging.

Applicable Codes

City of Prospect Heights Municipal Ordinance (http://www.prospect-heights.il.us/)

International Residential Code (www.iccsafe.org)

International Fire Code (www.iccsafe.org)

National Electric Code (www.nfpa.org)

Com Ed 800-892-0123

Inspections

- *Inspections are scheduled for A.M. or P.M. Monday through Friday with 24 hours advance notice. Call 847-398-6070 x 211 before 5:00 P.M. the day before you want your inspection.
- *Rough inspection
- *Final inspection

Department of Building & Zoning

8 North Elmhurst Road Prospect Heights Illinois, 60070-6070

Office: 847/398-6070 x

21

Fax: 847/590-1854

http://www.prospectheights.il.us/

I have read and rev	iewed these	requirements.
---------------------	-------------	---------------