

# Lawn Sprinkler Guideline



## What to Submit

- \*Completed application.
- \*Plat of plats survey (3 copies)
- \*3 copies of a site plan showing the proposed exact location; this may be written on a plat of survey
- \*Provide manufactures' installation instructions
- \*Provide manufactures' specs, include the required RPZ type
- \*Irrigation contractors must have the following:
  - -Illinois Irrigation License
  - -Bond or License Permit and liability insurance
  - -One licensed plumber on contract retainer for every five (5) irrigation installers (provide state license)
- \*Confirm clarify in writing that this proposal is NOT in a floodplain, easement, or floodway

#### **Rules & Restrictions**

- \*No sprinklers allowed in the easements or Right-of-Ways
- \*RPZ are required to be installed and inspected annually by a private state licensed plumber
- \*Maintain a 5' setback from the lot lines
- \*Sprinkler heads are to spray inward and not toward neighboring properties
- \*The house connection shall be galvanized or type "L" copper
- \*New construction sites require final topographic survey approval by the Engineering Department before the sprinkler permit is issued
- \*New construction requires a final topographical survey approved by the city engineer prior permit issuance

## **Inspections**

\*Inspections are scheduled for A.M. or P.M. Monday through Friday with 24 hours advance notice. Call 847-398-6070 x 211 before 5:00 P.M. the day before you want your inspection. Same day re-inspections are not available.

\*Call J.U.L.I.E. (800-892-0123) before digging.

\*Final inspection required with a RPZ certificate

# Applicable Codes

\*City of Prospect Heights Municipal Ordinance (http://www.prospectheights.il.us/)

\*Illinois State Plumbing Code (www.idph.state.il.us)

Department of Building & Zoning

8 North Elmhurst Road, Prospect Heights Illinois, 60070-6070

Office: 847/398-6070 x 211

Fax: 847/590-1854

http://www.prospectheights.il.us/

T	have rea	d and	reviewed	these	requiremen	tc
_	mave rea					